

# ELECTROSOFT BICOLOR CLASS 1

Product Number: 2091075

For electrical work with a maximum voltage of 7500 volts. Must be used with a leather overglove.

Bicolor for easier detection of defects before use (i.e. accidental cuts, perforations, abrasions..)

## Overview

### Reference Number

2091075

### Product Type

Gloves

### Range

Electrical Protection

### Line

Latex

### Brand

Honeywell

### Brand formerly known as

ELECTROSOFT

### Industry

Energy or Electricity /Maintenance /Telecoms

### Product Use

For electrical work with a maximum voltage of 7500 volts. Must be used with a leather overglove.

Bicolor for easier detection of defects before use (i.e. accidental cuts, perforations, abrasions..). Arc flash rating performed by a third party lab: box test 4KA/30cm.



## FEATURES & BENEFITS

### Feature

- Natural latex insulating glove
- Bi-color (beige in/ red out)
- Cut edge
- Category RC
- Box test: 7kA/300 mm

### Benefit

- Comfort.
- Its ergonomic shape and lightly powdered interior make the glove easy to slip on and off.

### Resistance

- Its natural latex base offers high dielectric characteristics.
- Its thickness (1,5 mm) ensures good dexterity while offering protection up to 7500 volts of use.

### Safety

- It must be used with a leather overglove.
- Bi-color (beige in/ red out) for easier detection of defects before use (i.e. accidental cuts, perforations, abrasions..)

# ELECTROSOFT BICOLOR CLASS 1 Technical Specifications

## DESCRIPTION

**CE Category:** III Irreversible risks

**In accordance with standards :**

EN 60903-2003

CEI 903-2002

**Characteristics :**

Natural latex insulating glove

**Bi-color:**(beige in/ red out)

**Category:** RC

**Box test :** 7kA/30 cm

## PRODUCT TECHNOLOGY

Dipped Gloves

**Glove/liner color:** Bi-color beige in/ red out

**Coating Type:** Latex

**Length:** 41 cm

**Thickness:** 1.5 mm

**Harmlessness:** In conformity with the European standards

**Sizes:** 8 to 12

## PACKAGING LABEL

**Tagging**

**Classe:** 1

**Categorie:** AZC

EN 60903-2003

ELECTROSOFT

## CERTIFICATIONS

**E.C. Declaration of Conformity**

**EC Category PPE:** 3

**Quality Assurance:** ISO 9001 / 2000

**EC Certificate Number:** 7007

**EC Attestation:** EC certificate

**EC Attestation Number:** 7007

## ADDITIONAL INFORMATION

**User Manual**

**User Information Sheet:** On the polybag.

## MAINTENANCE

**Life Cycle:** Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

## STORAGE INFORMATION

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C and 21°C.

## CARE INSTRUCTIONS

**Inspection :** Before each use, carry out a visual inspection and check the glove inflation.

Any puncture or perforation makes the gloves unusable.

**Precautions :** Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

**Cleaning :** Use water and soap. Dry below 65°C with ambient humidity.

## Honeywell Industrial Safety India

Honeywell International India Pvt. Ltd.

Unitech Trade Center, 1st Floor,

Gurgaon - 122002, Haryana, India

Telephone: +91 124 4975000

Fax: +91 124 4752750

Email id: hsp-india@honeywell.com

www.honeywellsafety.com

www.partnerconnect.honeywell.com