

ELECTROSOFT RED CLASS 0

Product Number: 2091074

For electrical work with a maximum voltage of 1000 volts. Must be used with a leather overglove.

Bicolor for easier detection of defects before use (i.e. accidental cuts, perforations, abrasions..)

Overview

Reference Number

2091074

Product Type

Gloves

Range

Electrical Protection

Line

Latex

Brand

Honeywell

Brand formerly known as

ELECTROSOFT

Industry

Energy or Electricity /Maintenance /Telecoms

Product Use

For electrical work with a maximum voltage of 1000 volts. Must be used with a leather overglove.

Bicolor for easier detection of defects before use (i.e. accidental cuts, perforations, abrasions..). Arc flash rating performed by a third party lab: box test 4KA/30cm lab: box test 4KA/30cm.



FEATURES & BENEFITS

Feature

- Natural latex insulating glove
- Bi-color (beige in/ red out)
- Cut edge
- Category: RC
- Box test: 7kA/300 mm

Benefit

- Comfort
 - Its ergonomic shape and lightly powdered interior make the glove easy to slip on and off.
- ### Resistance
- Its natural latex base offers high dielectric characteristics.
 - Its thickness (1 mm) ensures good dexterity while offering protection up to 1000 volts of use.

Safety

- It must be used with a leather overglove.
- Bi-color (beige in/ red out) for easier detection of defects before use (i.e. accidental cuts, perforations, abrasions..)

ELECTROSOFT BICOLOR CLASS 0 Technical Specifications

DESCRIPTION

CE Category: III Irreversible risks

In accordance with standards :

EN 60903-2003

CEI 903-2002

Characteristics :

Natural latex insulating glove

Bi-color:(beige in/ red out)

Category: RC

Box test : 7kA/30 cm and (with cotton under glove) 4kA 15 cm

PRODUCT TECHNOLOGY

Dipped Gloves

Glove/liner color: Bi-color beige in/ red out

Coating Type: Latex

Length:36 cm

Thickness: 1mm

Harmlessness: In conformity with the European standards

Sizes: 8 to 12

PACKAGING LABEL

Tagging

Classe: 0

Categorie: RC

EN 60903-2003

ELECTROSOFT

CERTIFICATIONS

E.C. Declaration of Conformity

EC Category PPE: 3

Quality Assurance: ISO 9001 / 2000

EC Certificate Number: 7005

EC Attestation: EC Certificate

EC Attestation Number: 7005

ADDITIONAL INFORMATION

User Manual

User Information Sheet: On the polybag.

MAINTENANCE

Life Cycle: Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

STORAGE INFORMATION

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C and 21°C.

CARE INSTRUCTIONS

Inspection : Before each use, carry out a visual inspection and check the glove inflation.

Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : Use water and soap. Dry below 65°C with ambient humidity.

Honeywell Industrial Safety India

Honeywell International India Pvt. Ltd.

Unitech Trade Center, 1st Floor,

Gurgaon - 122002, Haryana, India

Telephone: +91 124 4975000

Fax: +91 124 4752750

Email id: hsp-india@honeywell.com

www.honeywellsafety.com

www.partnerconnect.honeywell.com